

## MANUAL SUPPLEMENT

**Vibraswitch**

**Model 366**

### SPECIAL OPTIONS

**ROBERTSHAW  
TENNESSEE DIVISION**

**P.O. Box 400  
Knoxville, TN 37901-0400**

**Telephone (615) 546-0550**


**NUMBER  
909SC719B**

**Jan 3, 1995  
BRZ-8-206-603-606-607-  
608-692  
COS 91063**

### GENERAL:

This Manual Supplement should be read completely and retained in a secure place for future reference.

Refer to Instruction Manual No. 909GF084 and all other supplements which may have been supplied with the instrument for all instructions and specifications except as may be noted in this supplement.



### SWITCH OPTIONS:

A = SPDT

D = DPDT

### RESET COIL VOLTAGES:

0 = No reset Coil

1 = 12 VDC @ 1.5 A

2 = 24 VDC @ 0.5 A

3 = 240 VDC @ 0.3 A

4 = 48 VDC @ 0.2 A

7 = 117 VDC @ 0.14 A

8 = 120 VAC @ 0.3 A