

MANUAL SUPPLEMENT

Vibraswitch 366SA001 SERIES

Model 366-D With Special Reset Coil Voltage

ROBERTSHAW
TENNESSEE DIVISION

P.O. Box 400
Knoxville, TN 37901-0400

Telephone (615) 546-0550

INSTRUMENT PART NUMBER: 366SA001 WITH SUFFIX NUMBER

Refer to Instruction Manual No. 909GF084 and all other supplements which may have been supplied with the instrument for all instructions and specifications except as may be noted in this supplement.

Instruments listed in this supplement are not CSA Certified.

It is recommended that the field wiring which may come into contact with the large resistor located inside of the Vibraswitch have an insulation rated 125 degrees centigrade or higher.

PART NUMBER 366SA001-01:

This instrument is the same as Model No. 366-D8 except for the following:

1. Reset coil voltage is 240 VAC.

NUMBER
909SC707C

Oct 18, 1993
COS 88955 8-65-206-
BRZ-J6