

MANUAL SUPPLEMENT

Vibraswitch 900SA724 SERIES

Model 366-A With Special Reset Coil Voltage

**ROBERTSHAW
TENNESSEE DIVISION**

**P.O. Box 400
Knoxville, TN 37901-0400
Telephone (615) 546-0550**

**NUMBER
909SC708D**

**Oct 18, 1993
COS 88955 8-65-206-BRZ-J6**

INSTRUMENT PART NUMBER: 900SA724 WITH AND WITHOUT SUFFIX NUMBER

Refer to Instruction Manual No. 909GF084 and all other supplements which may have been supplied with the instrument for all instructions and specifications except as may be noted in this supplement.

Instruments listed in this supplement are not CSA Certified.

It is recommended that the field wiring which may come into contact with the large resistor located inside of the Vibraswitch have an insulation rated 125 degrees centigrade or higher.

PART NUMBER 900SA724:

This instrument is the same as Model No. 366-A8 except for the following:

1. Reset coil voltage is 240 VAC.
2. A 240 VAC space heater is added.

PART NUMBER 900SA724-01:

This instrument is the same as Model No. 366-A8 except for the following:

1. Reset coil voltage is 240 VAC.